

# Test Certificate

Testing Date RangeFrom: 04/07/2018 To: 04/07/2018  
\*Note - Items were not function tested

<b>Client:</b> Allsorts of Fun	<b>Site:</b> 166 Links Road	<b>Location:</b> KITCHEN
Asset ID: 171814	Description: 2W EXT LEAD	Make:
User: ALEXIS	Test Instrument: Seaward Apollo 600 40H-0474	Model:
Comments:		

Test Type	Date	Result	Unit	Status
Plug	04/07/2018			Pass
Flex	04/07/2018			Pass
Enclosure	04/07/2018			Pass
Environment	04/07/2018			Pass
Socket	04/07/2018			Pass
Switch	04/07/2018			Pass
Voltage	04/07/2018	230	V	Information
IEC Lead Continuity	04/07/2018	0.18	ohm	Pass
Insulation Voltage	04/07/2018	500	V	Information
Insulation	04/07/2018	> 19.99	MOhm	Pass
IEC Lead Polarity	04/07/2018			Pass
Overall: Pass				

Asset ID: 171815	Description: 30M CABLE REEL	Make: JCB
User: ALEXIS	Test Instrument: Seaward Apollo 600 40H-0474	Model:
Comments:		

Test Type	Date	Result	Unit	Status
Plug	04/07/2018			Pass
Flex	04/07/2018			Pass
Enclosure	04/07/2018			Pass
Environment	04/07/2018			Pass
Socket	04/07/2018			Pass
Switch	04/07/2018			Pass
Voltage	04/07/2018	230	V	Information
IEC Lead Continuity	04/07/2018	0.49	ohm	Pass
Insulation Voltage	04/07/2018	500	V	Information
Insulation	04/07/2018	> 19.99	MOhm	Pass
IEC Lead Polarity	04/07/2018			Pass
Overall: Pass				

Asset ID: 171816	Description: AC ADAPTER	Make:
User: ALEXIS	Test Instrument: Seaward Apollo 600 40H-0474	Model:
Comments:		

Test Type	Date	Result	Unit	Status
Plug	04/07/2018			Pass
Flex	04/07/2018			Pass
Enclosure	04/07/2018			Pass
Environment	04/07/2018			Pass
Socket	04/07/2018			Pass
Switch	04/07/2018			Pass
Voltage	04/07/2018	230	V	Information
Insulation Voltage	04/07/2018	250	V	Information
Insulation	04/07/2018	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 171817	Description: AC ADAPTER	Make:
User: ALEXIS	Test Instrument: Seaward Apollo 600 40H-0474	Model:
Comments:		

Test Type	Date	Result	Unit	Status
Plug	04/07/2018			Pass
Flex	04/07/2018			Pass
Enclosure	04/07/2018			Pass
Environment	04/07/2018			Pass
Socket	04/07/2018			Pass
Switch	04/07/2018			Pass
Voltage	04/07/2018	230	V	Information
Insulation Voltage	04/07/2018	250	V	Information
Insulation	04/07/2018	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 171818	Description: AC ADAPTER	Make:
User: ALEXIS	Test Instrument: Seaward Apollo 600 40H-0474	Model:
Comments:		

Test Type	Date	Result	Unit	Status
Plug	04/07/2018			Pass
Flex	04/07/2018			Pass
Enclosure	04/07/2018			Pass
Environment	04/07/2018			Pass
Socket	04/07/2018			Pass
Switch	04/07/2018			Pass
Voltage	04/07/2018	230	V	Information

Signed By: 



# Test Certificate

Testing Date RangeFrom: 04/07/2018 To: 04/07/2018  
\*Note - Items were not function tested

Insulation Voltage	04/07/2018	250	V	Information
Insulation	04/07/2018	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 171819	Description: LIGHT CONTROL	Make: AXA	Model:
User: ALEXIS	Test Instrument: Seaward Apollo 600 40H-0474	Comments:	

Test Type	Date	Result	Unit	Status
Plug	04/07/2018			Pass
Flex	04/07/2018			Pass
Enclosure	04/07/2018			Pass
Environment	04/07/2018			Pass
Socket	04/07/2018			Pass
Switch	04/07/2018			Pass
Voltage	04/07/2018	230	V	Information
Earth Continuity	04/07/2018	0.23	ohm	Pass
Insulation Voltage	04/07/2018	500	V	Information
Insulation	04/07/2018	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 171820	Description: AUDIO PA SYSTEM	Make: COOMBER	Model: 2410
User: ALEXIS	Test Instrument: Seaward Apollo 600 40H-0474	Comments:	

Test Type	Date	Result	Unit	Status
Plug	04/07/2018			Pass
Flex	04/07/2018			Pass
Enclosure	04/07/2018			Pass
Environment	04/07/2018			Pass
Socket	04/07/2018			Pass
Switch	04/07/2018			Pass
Voltage	04/07/2018	230	V	Information
Insulation Voltage	04/07/2018	250	V	Information
Insulation	04/07/2018	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 171821	Description: BLOWER	Make: IBBONS	Model: AOMO150
User: ALEXIS	Test Instrument: Seaward Apollo 600 40H-0474	Comments:	

Test Type	Date	Result	Unit	Status
Plug	04/07/2018			Pass
Flex	04/07/2018			Pass
Enclosure	04/07/2018			Pass
Environment	04/07/2018			Pass
Socket	04/07/2018			Pass
Switch	04/07/2018			Pass
Voltage	04/07/2018	230	V	Information
Earth Continuity	04/07/2018	0.06	ohm	Pass
Insulation Voltage	04/07/2018	500	V	Information
Insulation	04/07/2018	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 171822	Description: 16AMP POWER LEAD	Make:	Model:
User: ALEXIS	Test Instrument: Seaward Apollo 600 40H-0474	Comments:	

Test Type	Date	Result	Unit	Status
Plug	04/07/2018			Pass
Flex	04/07/2018			Pass
Enclosure	04/07/2018			Pass
Environment	04/07/2018			Pass
Socket	04/07/2018			Pass
Switch	04/07/2018			Pass
Voltage	04/07/2018	230	V	Information
Earth Continuity	04/07/2018	0.04	ohm	Pass
Insulation Voltage	04/07/2018	500	V	Information
Insulation	04/07/2018	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 171823	Description: 4W EXT LEAD	Make:	Model:
User: ALEXIS	Test Instrument: Seaward Apollo 600 40H-0474	Comments:	

Test Type	Date	Result	Unit	Status
Plug	04/07/2018			Pass
Flex	04/07/2018			Pass
Enclosure	04/07/2018			Pass
Environment	04/07/2018			Pass
Socket	04/07/2018			Pass

Signed By: 

# Test Certificate

Testing Date RangeFrom: 04/07/2018 To: 04/07/2018

**\*Note - Items were not function tested**

Switch	04/07/2018			Pass
Voltage	04/07/2018	230	V	Information
IEC Lead Continuity	04/07/2018	0.26	ohm	Pass
Insulation Voltage	04/07/2018	500	V	Information
Insulation	04/07/2018	> 19.99	MOhm	Pass
IEC Lead Polarity	04/07/2018			Pass

Overall: Pass

User: ALEXIS Test Instrument: Seaward Apollo 600 40H-0474 Comments:

Total Tests: 10

Signed By: 