

Test Certificate

Testing Date RangeFrom: 28/06/2017 To: 28/06/2017
*Note - Items were not function tested

Client: Allsorts of Fun	Site: 166 Links Road	Location: KITCHEN
Asset ID: 103697	Description: SPEAKER	Make: COOMBER
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Model: 2070 C
Comments:		

Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
Earth Continuity	28/06/2017	0.25	ohm	Pass
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 103698	Description: SPEAKER	Make: COOMBER	Model: 2410
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:	

Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 103699	Description: AC ADAPTER	Make: ASIAN POWER DEVICES	Model: WA 18G12K
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:	

Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 103700	Description: AC ADAPTER	Make:	Model:
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:	

Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass
Overall: Pass				

Asset ID: 103701	Description: EXT LEAD	Make:	Model:
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:	

Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
IEC Lead Continuity	28/06/2017	0.47	ohm	Pass
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass

Signed By: 



Test Certificate

Testing Date Range From: 28/06/2017 To: 28/06/2017
*Note - Items were not function tested

IEC Lead Polarity 28/06/2017 Pass
Overall: Pass

Asset ID: 103702	Description: EXT LEAD	Make:	Model:
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:	

Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
IEC Lead Continuity	28/06/2017	0.15	ohm	Pass
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	28/06/2017			Pass

Overall: Pass

Asset ID: 103703	Description: AMPLIFIER	Make: SHOW	Model: SA18
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:	

Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
Earth Continuity	28/06/2017	0.08	ohm	Pass
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 103704	Description: FAN	Make: SB	Model:
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:	

Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
Earth Continuity	28/06/2017	0.13	ohm	Pass
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 103705	Description: AC ADAPTER	Make: MAGELLAN GROUP LIMITED	Model:
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:	

Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 103706	Description: IEC LEAD	Make:	Model:
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:	

Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass

Signed By: 

Test Certificate

Testing Date RangeFrom: 28/06/2017 To: 28/06/2017
*Note - Items were not function tested

Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
IEC Lead Continuity	28/06/2017	0.08	ohm	Pass
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	28/06/2017			Pass

Overall: Pass

Asset ID: 103707	Description: IEC LEAD	Make:	Model:
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:	

Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
IEC Lead Continuity	28/06/2017	0.07	ohm	Pass
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	28/06/2017			Pass

Overall: Pass

Asset ID: 103708	Description: AMPLIFIER	Make: HH	Model:
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:	

Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
Earth Continuity	28/06/2017	0.03	ohm	Pass
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 103709	Description: EXT LEAD	Make:	Model:
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:	

Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
IEC Lead Continuity	28/06/2017	0.27	ohm	Pass
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	28/06/2017			Pass

Overall: Pass

Asset ID: 103710	Description: POWER SUPPLY	Make:	Model:
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:	

Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
Earth Continuity	28/06/2017	0.19	ohm	Pass
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass

Overall: Pass

Signed By: 

Test Certificate

Testing Date Range From: 28/06/2017 To: 28/06/2017
*Note - Items were not function tested

Asset ID: 103711	Description: IEC LEAD	Make:	Model:	
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:		
Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
IEC Lead Continuity	28/06/2017	0.01	ohm	Pass
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	28/06/2017			Pass
Overall: Pass				

Asset ID: 103712	Description: IEC LEAD	Make:	Model:	
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:		
Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
IEC Lead Continuity	28/06/2017	< 0.010	ohm	Pass
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	28/06/2017			Pass
Overall: Pass				

Asset ID: 103713	Description: IEC LEAD	Make:	Model:	
User: Giovanni	Test Instrument: Seaward Apollo 600 06J-0875	Comments:		
Test Type	Date	Result	Unit	Status
Plug	28/06/2017			Pass
Flex	28/06/2017			Pass
Enclosure	28/06/2017			Pass
Environment	28/06/2017			Pass
Socket	28/06/2017			Pass
Switch	28/06/2017			Pass
Voltage	28/06/2017	230	V	Information
IEC Lead Continuity	28/06/2017	< 0.010	ohm	Pass
Insulation Voltage	28/06/2017	250	V	Information
Insulation	28/06/2017	> 19.99	MOhm	Pass
IEC Lead Polarity	28/06/2017			Pass
Overall: Pass				

User: Giovanni Test Instrument: Seaward Apollo 600 06J-0875 Comments:

Total Tests: 17

Signed By: 