

# Test Certificate



Testing Date RangeFrom: 30/06/2016 To: 30/06/2016

**\*Note - Items were not function tested**

<b>Client:</b> Allsorts of Fun	<b>Site:</b> 166 Links Road	<b>Location:</b> OFFICE
Asset ID: 2651	Description: PORTABLE PA CD SYSTEM	Make: COOMBER
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Model: 2080 C
Comments:		

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass
Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information
Earth Continuity	30/06/2016	< 0.010	ohm	Pass
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 2652	Description: PORTABLE PA CD SYSTEM	Make: COOMBER
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Model: 2410
Comments:		

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass
Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 2653	Description: POWER LEAD	Make:
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Model:
Comments:		

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass
Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information
IEC Lead Continuity	30/06/2016	0.16	ohm	Pass
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass
IEC Lead Polarity	30/06/2016			Pass

Overall: Pass

Asset ID: 2654	Description: PUMP	Make: SILVER BOX
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Model: 15
Comments:		

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass
Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information
Earth Continuity	30/06/2016	0.04	ohm	Pass
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 2655	Description: AMP	Make: HH
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Model:
Comments:		

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass
Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information

**Signed By:**



# Test Certificate



Testing Date RangeFrom: 30/06/2016 To: 30/06/2016

**\*Note - Items were not function tested**

Earth Continuity	30/06/2016	0.13	ohm	Pass
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 2656	Description: POWER LEAD	Make:	Model:
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Comments:	

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass
Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 2657	Description: CD PLAYER	Make: PANASONIC	Model:
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Comments:	

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass
Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 2658	Description: POWER LEAD	Make:	Model:
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Comments:	

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass
Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information
IEC Lead Continuity	30/06/2016	0.12	ohm	Pass
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass
IEC Lead Polarity	30/06/2016			Pass

Overall: Pass

Asset ID: 2659	Description: AC ADAPTOR	Make:	Model:
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Comments:	

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass
Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information
Earth Continuity	30/06/2016	0.04	ohm	Pass
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 2660	Description: DJ DECKS	Make: NUMARK	Model: CD MIX 1
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Comments:	

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass

Signed By:



# Test Certificate



Testing Date RangeFrom: 30/06/2016 To: 30/06/2016

**\*Note - Items were not function tested**

Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information
Earth Continuity	30/06/2016	0.26	ohm	Pass
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 2661	Description: EXT LEAD	Make:	Model:
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Comments:	

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass
Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information
IEC Lead Continuity	30/06/2016	0.28	ohm	Pass
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass
IEC Lead Polarity	30/06/2016			Pass

Overall: Pass

Asset ID: 2662	Description: EXT LEAD	Make:	Model:
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Comments:	

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass
Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information
IEC Lead Continuity	30/06/2016	0.49	ohm	Pass
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass
IEC Lead Polarity	30/06/2016			Pass

Overall: Pass

Asset ID: 2663	Description: CONTROLLER	Make: AX4	Model: 1925
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Comments:	

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass
Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information
Earth Continuity	30/06/2016	0.03	ohm	Pass
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass

Overall: Pass

Asset ID: 2664	Description: AC ADAPTOR	Make:	Model:
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Comments:	

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass
Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass

Overall: Pass

Signed By:



# Test Certificate



Testing Date RangeFrom: 30/06/2016 To: 30/06/2016

**\*Note - Items were not function tested**

Asset ID: 2665	Description: MIC RECIEVER	Make: PROSOUND	Model: N41QR
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Comments:	
Test Type	Date	Result	Unit Status
Plug	30/06/2016		Pass
Flex	30/06/2016		Pass
Enclosure	30/06/2016		Pass
Environment	30/06/2016		Pass
Socket	30/06/2016		Pass
Switch	30/06/2016		Pass
Voltage	30/06/2016	230	V Information
Insulation Voltage	30/06/2016	500	V Information
Insulation	30/06/2016	> 19.99	MOhm Pass
Overall: Pass			

Asset ID: 2666	Description: AC ADAPTOR	Make:	Model:
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Comments:	
Test Type	Date	Result	Unit Status
Plug	30/06/2016		Pass
Flex	30/06/2016		Pass
Enclosure	30/06/2016		Pass
Environment	30/06/2016		Pass
Socket	30/06/2016		Pass
Switch	30/06/2016		Pass
Voltage	30/06/2016	230	V Information
Insulation Voltage	30/06/2016	500	V Information
Insulation	30/06/2016	> 19.99	MOhm Pass
Overall: Pass			

Asset ID: 2667	Description: BUBBLE MACHINE	Make:	Model: G002GKB
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Comments:	
Test Type	Date	Result	Unit Status
Plug	30/06/2016		Pass
Flex	30/06/2016		Pass
Enclosure	30/06/2016		Pass
Environment	30/06/2016		Pass
Socket	30/06/2016		Pass
Switch	30/06/2016		Pass
Voltage	30/06/2016	230	V Information
Insulation Voltage	30/06/2016	500	V Information
Insulation	30/06/2016	> 19.99	MOhm Pass
Overall: Pass			

Asset ID: 2668	Description: POWER LEAD	Make:	Model:
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Comments:	
Test Type	Date	Result	Unit Status
Plug	30/06/2016		Pass
Flex	30/06/2016		Pass
Enclosure	30/06/2016		Pass
Environment	30/06/2016		Pass
Socket	30/06/2016		Pass
Switch	30/06/2016		Pass
Voltage	30/06/2016	230	V Information
IEC Lead Continuity	30/06/2016	0.15	ohm Pass
Insulation Voltage	30/06/2016	500	V Information
Insulation	30/06/2016	> 19.99	MOhm Pass
IEC Lead Polarity	30/06/2016		Pass
Overall: Pass			

Asset ID: 2669	Description: POWER LEAD	Make:	Model:
User: NICK	Test Instrument: Seaward Apollo 600 44G-0497	Comments:	
Test Type	Date	Result	Unit Status
Plug	30/06/2016		Pass
Flex	30/06/2016		Pass
Enclosure	30/06/2016		Pass
Environment	30/06/2016		Pass
Socket	30/06/2016		Pass
Switch	30/06/2016		Pass
Voltage	30/06/2016	230	V Information
IEC Lead Continuity	30/06/2016	0.17	ohm Pass
Insulation Voltage	30/06/2016	500	V Information
Insulation	30/06/2016	> 19.99	MOhm Pass

Signed By:



# Test Certificate



Testing Date RangeFrom: 30/06/2016 To: 30/06/2016

**\*Note - Items were not function tested**

IEC Lead Polarity 30/06/2016 Pass  
Overall: Pass

Asset ID: 2670 Description: POWER LEAD Make: Model:

User: NICK Test Instrument: Seaward Apollo 600 44G-0497 Comments:

Test Type	Date	Result	Unit	Status
Plug	30/06/2016			Pass
Flex	30/06/2016			Pass
Enclosure	30/06/2016			Pass
Environment	30/06/2016			Pass
Socket	30/06/2016			Pass
Switch	30/06/2016			Pass
Voltage	30/06/2016	230	V	Information
IEC Lead Continuity	30/06/2016	0.14	ohm	Pass
Insulation Voltage	30/06/2016	500	V	Information
Insulation	30/06/2016	> 19.99	MOhm	Pass
IEC Lead Polarity	30/06/2016			Pass

Overall: Pass

User: NICK Test Instrument: Seaward Apollo 600 44G-0497 Comments:

Total Tests: 20

Signed By:

PAT Central LTD, 20-22 Wenlock Road, London, N1 7GU  
Tel: 0800 612 4879 Email: info@patcentral.co.uk

